

DECLARATION OF CONFORMITY

We, Swegon AB

Declare under our sole responsibility that the product:

Circular fire damper IGNIS-C-EI120

To which this declaration relates, is in compliance with all the applicable essential requirements according to EN 15650:2010, and other provisions of the European Council Directive (89/106/EEC)

IGNIS-C-EI120 Circular fire damper				
Actuator:				
<ul style="list-style-type: none"> - CFTH: Fusible link mechanism - B(L)F(T): General purpose actuator 				
Fire resistance according to EN 1366-2 and classifications according to EN 13501-3:				
Range	Type	Wall	Sealing	Classification
Ø 200 up to Ø 630	Rigid wall	Aerated concrete min. 100 mm	With mortar	EI 120 (v _e i ↔ o) S - (500 Pa)
	Flexible wall	Metal stud gypsum plasterboard 100 mm	GKA	EI 60 (v _e i ↔ o) S - (500 Pa)
			GKF	
		Gypsum blocs min 70 mm	With glue	EI 120 (v _e i ↔ o) S - (500 Pa)
	Rigid floor	Aerated concrete min 150 mm	With mortar	EI 120 (h _o i ↔ o) S - (500 Pa)
Nominal activation conditions/sensitivity according to ISO 10294-4:			Pass	
<ul style="list-style-type: none"> - sensing element load bearing capacity - sensing element response temperature 				
Response delay (response time) according to EN 1366-2:			Pass	
<ul style="list-style-type: none"> - closure time 				
Operational reliability according to EN 1366-2:			Pass	
<ul style="list-style-type: none"> - cycling 				
Durability of response delay according to EN 1366-2:			Pass	
<ul style="list-style-type: none"> - sensing element response temperature and load bearing capacity 				
Durability of operational reliability according to EN 15650:			CFTH - 50 cycles - passed	
<ul style="list-style-type: none"> - open and closing cycle 			B(L)F(T) - 10 000 cycles - passed	
Protection against corrosion according to EN 60068-2-52:			Pass	
Damper casing leakage according to EN 1751:			Min. class B	

Declaration based on certificate of conformity BC1-606-0464-15650.41-2517 of BCCA.



Date & place of issue:
 Kvänum, 1 February 2012

Signature:
 Anders Eriksson
 Technical Marketing Manager